

## Chapters SPS 361 to 366

### APPENDIX A

The material contained in this appendix is for clarification purposes only and is numbered to correspond to the number of the rule as it appears in the text of the code.

**A-361.03 (5) (b) Lower thresholds for municipalities with preexisting stricter sprinkler ordinances.** Section 101.14 (4m) (d) and (e), Stats., provides the following thresholds above which fire sprinkler protection or 2-hour fire-resistance can be required by a municipality with a preexisting stricter sprinkler ordinance.

Class of Construction	Total Floor Area Within Individual Dwelling Units	Number of Units	Total Floor Area of Nondwelling Unit Portions (Common use areas, such as corridors, stairways, basements, cellars, vestibules, community rooms, laundry rooms, pools, etc.)
Type IA	8,000 sq ft	8 units	12,000 sq ft
Type IB			10,000 sq ft
Type IIA			8,000 sq ft
Type IIB			5,600 sq ft
Type III			
Type IV			
Type VA			
Type VB			4,800 sq ft

The Department, based on ordinances forwarded by municipalities (and checked by Industry Services staff for conformance with the preexisting sprinkler ordinance criteria), or based on other provided information, believes the following municipalities have preexisting stricter sprinkler ordinances. Other municipalities may also have preexisting stricter sprinkler ordinances.

Appleton  
Brookfield  
Franklin  
Greendale  
Greenfield

Madison  
Menomonee Falls  
Monona  
Mount Pleasant

Muskego  
New Berlin  
Oak Creek  
Racine

Shorewood Hills  
Sussex  
Thiensville  
West Allis  
West Bend